



Intelligent PDU

S.no	Description
1	1 Phase / 3 Phase
2	IP Addressable
3	RS485 (MODBUS)
4	Sensor Connection (T/H)
5	Voltage / Amp Measurement
6	TCP/IP/SNMP/TELNET
7	CE Certified



Customizable Models (IPDU)

S.NO	DESCRIPTION	DETAILS
1	Number of Outlets	Maximum number of Outlets based on Requirements
2	Types of Outputs	Bs 1363 – UK / IEC C13 / IEC C19
3	Types of Inputs	IEC 60309 16A / 32A / UK / IEC C14 / IEC C20
4	Phase	1 Phase / 3 Phase
5	Max Amp (IPDU)	13A/16A/32A
6	Types of Protection	MCB/RCBO/OVERLOAD/SPD
7	Cable Sizes	3cx1.5mm/3cx2.5mm/3cx4mm/5cx2.5mm/5cx4mm Based on Requirements
8	Colour	Black
9	Number of Sensor Connections	1 In the Device (Default) / Can extend up to 6 By Extension Module /

For More Details About the IPDU Meter Kindly refer to the IPDU Manual / Shared separately
IPDU'S Are mostly Customized based on the Customer Enquiry.

Safix IPDU User Interface:

SAFIX®

User Name

Password

Log On

Status Configuratio Network System

Host PDU Status

Select # Host

System Info

Model IPDUV1
Number
Version 1.0.13

Real-Time Data

Voltage	225.5V	Current	0.026A
Active Power	0.002kW	Power Factor	0.341
Energy	0.000kWh	Frequency	60.003Hz

Sensor

Temperature1 -	Humidity1 -	Dew point1 -
Temperature2 -	Humidity2 -	Dew point2 -
Temperature3 -	Humidity3 -	Dew point3 -
Temperature4 -	Humidity4 -	Dew point4 -

Alarm Status

Voltage	Normal	Current	Normal
Temperature1 -		Humidity1	-
Temperature2 -		Humidity2	-
Temperature3 -		Humidity3	-
Temperature4 -		Humidity4	-
IO Sensor 1 -		IO Sensor 2	-
IO Sensor 3 -		IO Sensor 4	-

[Status](#) [Configuratio](#) [Network](#) [System](#)

Host PDU Configure

Select # Host ▼

Device Alarm Threshold

Beep Alarm ON ▼

Voltage	Upper Limit	<input type="text" value="300.0"/>	V
	Lower Limit	<input type="text" value="0.0"/>	V

Current	Upper Limit	<input type="text" value="32.00"/>	A
	Lower Limit	<input type="text" value="0.00"/>	A

Apply

Sensors Alarm Threshold

Temperature1	Upper Limit	<input type="text" value="90.0"/>	°C
	Lower Limit	<input type="text" value="0.0"/>	°C

Humidity1	Upper Limit	<input type="text" value="90.0"/>	%RH
	Lower Limit	<input type="text" value="0.0"/>	%RH

Temperature2	Upper Limit	<input type="text" value="90.0"/>	°C
	Lower Limit	<input type="text" value="0.0"/>	°C

Humidity2	Upper Limit	<input type="text" value="90.0"/>	%RH
	Lower Limit	<input type="text" value="0.0"/>	%RH

Temperature3	Upper Limit	<input type="text" value="90.0"/>	°C
	Lower Limit	<input type="text" value="0.0"/>	°C

Humidity3	Upper Limit	<input type="text" value="90.0"/>	%RH
	Lower Limit	<input type="text" value="0.0"/>	%RH

Temperature4	Upper Limit	<input type="text" value="90.0"/>	°C
	Lower Limit	<input type="text" value="0.0"/>	°C

Humidity4	Upper Limit	<input type="text" value="90.0"/>	%RH
	Lower Limit	<input type="text" value="0.0"/>	%RH

Apply

Status Configuratio Network System

Update

Firmware/Certificate/Private No file chosen

TFTP Settings

TFTP Enable ☐

TFTP Server IP